



ARI-Armaturen Albert Richter GmbH & Co. KG • 33758 Schloß Holte-Stukenbrock

Scholzen GmbH  
Hardtweg 5  
71686 Remseck

Date : 2026-02-10  
Reference : 26/03565  
Manufacturer's  
Reference : 100761650 Pos. : 40  
Purchase  
Order Number : 353.2121  
Commission :

Inspection Certificate      DIN EN 10204-3.1      No.:      26/03565-      1      Page :      1

Quantity	Type of valve	Type number
1	ARI-Strainer Strainer - straight through with butt weld ends 1.0460 DN 50 Data sheet:050003-2.pdf Operating instruction:0040101000-2.pdf Nominal pressure : PN160 Inlet : DIN SE 60,3x4,0 outlet : DIN SE 60,3x4,0 Screen design : * Feinsieb Drain plug/plug screw : no Outside treatment : blue Funct. test certification : EN10204 3.1 Material certificate : EN 10204 3.1 . Dampfkühlstrecke <u>Label</u> 1 x 2.02 Test number : 26/03565	100971191-480800050G1

#### Manufacturer's works

ARI-Armaturen, Albert Richter GmbH & Co. KG, Am Eisenwerk 10, Tel.: +49 (0)5681-9910, 34576 Homberg-Holzhausen, GERMANY

Originator of the document : Quality Assurance Department

#### Material

We hereby confirm that the delivered products / articles were manufactured from the following materials.  
The chemical composition of the materials is according to DIN / EN.  
The results of the testings carried out are kept in our records.

Hexagon nut : 21CrMoV 5-7, 1.7709  
Cover : P250 GH, 1.0460  
Straight through body : P250 GH, 1.0460

Material (Continuation)

**Stud** : 21CrMoV 5-7, 1.7709

**Tests**

The following inspections were carried out on each product / article. No faults found.

Inspection request      DIN EN 12266 -1/-2  
Customer specification

**Visual and functional tests**

- Examination of order specification
- Examination of type + equipment
- Examination of marks
- Inspection of dimensions
- Inspection of surface
- Visual test
- Correctness of the material-certifications
- Functional Test

**Tests of stability and leakage**

- Shell strength test using water      1,5 x PN
- Shell tightness test using water      1,5 x PN

We hereby certify that the products / articles delivered under above mentioned order confirmation are in accordance with the purchase order.

Inspector : Frank Mergard, Head of Quality Inspection

